

**ADDENDUM 001
REQUEST FOR QUOTE
RFB NUMBER: D1-08-035**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original quote. The due date for receipt of quote remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Offerors. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Brenda Christie Procurement Agent
Contractor/Offeror Signature	Department of Transportation <i>Brenda Christie</i>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 8-30-07

Pre-Bid Meeting

Request for Bid No.: D1-08-035

Date: August 31, 2007

Time: 10:00:00 A.M.

Representative Name

Company

1. Ron Moutray Sr.

Lee Grover Construction

MoDOT Personnel:

Brenda Christie Procurement Agent

Jamie Wright Senior Facility Operations Specialist

RFQ Questions Submitted / Answers

Enclosed Walk Way

Note: Jamie add any information to these questions and answers if you need to.

1. Can you pour a slab across the footings?
Yes, if it ties into the piers.
2. Do you want (2) different colors?
Off White metal same as building (if available)
3. Has all of the electrical been taken care of?
Yes
4. Can the metal studs be wood?
No

Additions

Stair Treads will be added to finish out the steps. Treads and risers of stairs need to be covered with Anti-Slip rubber tread and riser. Color: Blue

Target Treads (#A605) or equal to.

- Outstanding flame retardant advantage
- ASTM-E84 Flame Spread Rating of 25 or less
- 12-1/2" deep
- 1/4" thick at front tapering to 5/32"
- Square nose only: Adjust –a-nose, must use Epoxy Nose Caulk
- Epoxy Adhesive required due to flame retardant material
- Color: Blue